

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
WATSON 2	1/10/2024 05:43	1/18/2024 16:31	70284329001	Lead	<1.0	5	ug/L
WATSON 3	1/10/2024 05:45	1/18/2024 16:35	70284329002	Lead	<1.0	5	ug/L
WATSON 5	1/10/2024 05:42	1/18/2024 16:43	70284329003	Lead	<1.0	5	ug/L
WATSON 7	1/10/2024 05:38	1/18/2024 16:45	70284329004	Lead	<1.0	5	ug/L
WATSON 8	1/10/2024 05:40	1/18/2024 16:46	70284329005	Lead	<1.0	5	ug/L
WATSON 9	1/10/2024 05:39	1/18/2024 16:48	70284329006	Lead	<1.0	5	ug/L
WATSON 11	1/10/2024 05:33	1/18/2024 16:49	70284329007	Lead	<1.0	5	ug/L
WATSON 12	1/10/2024 05:34	1/18/2024 16:51	70284329008	Lead	<1.0	5	ug/L
WATSON 13	1/10/2024 05:31	1/18/2024 16:52	70284329009	Lead	<1.0	5	ug/L
WATSON 14	1/10/2024 05:32	1/18/2024 16:54	70284329010	Lead	<1.0	5	ug/L
WATSON 15	1/10/2024 05:30	1/18/2024 16:56	70284329011	Lead	<1.0	5	ug/L
WATSON 17	1/10/2024 05:22	1/18/2024 16:57	70284329012	Lead	<1.0	5	ug/L
WATSON 18	1/10/2024 05:23	1/18/2024 17:02	70284329013	Lead	<1.0	5	ug/L
WATSON 19	1/10/2024 05:24	1/18/2024 17:03	70284329014	Lead	<1.0	5	ug/L
WATSON 21	1/10/2024 05:26	1/18/2024 17:05	70284329015	Lead	<1.0	5	ug/L
WATSON 27	1/10/2024 05:27	1/18/2024 17:06	70284329016	Lead	<1.0	5	ug/L
WATSON 28	1/10/2024 05:28	1/18/2024 17:08	70284329017	Lead	<1.0	5	ug/L
WATSON 36	1/10/2024 05:48	1/18/2024 17:10	70284329018	Lead	<1.0	5	ug/L
WATSON 38	1/10/2024 05:49	1/18/2024 17:11	70284329019	Lead	<1.0	5	ug/L
WATSON 39	1/10/2024 05:47	1/18/2024 17:13	70284329020	Lead	<1.0	5	ug/L
WATSON 40	1/10/2024 05:50	1/18/2024 17:20	70284329021	Lead	<1.0	5	ug/L
WATSON 42	1/10/2024 05:54	1/18/2024 17:25	70284329022	Lead	<1.0	5	ug/L
WATSON 44	1/10/2024 05:56	1/18/2024 17:29	70284329023	Lead	2.2	5	ug/L
WATSON 46	1/10/2024 05:57	1/18/2024 17:31	70284329024	Lead	<1.0	5	ug/L
WATSON 48	1/10/2024 06:05	1/18/2024 17:33	70284329025	Lead	5.0	5	ug/L
WATSON 49	1/10/2024 06:06	1/18/2024 17:34	70284329026	Lead	<1.0	5	ug/L
WATSON 50	1/10/2024 06:07	1/18/2024 17:39	70284329027	Lead	3.6	5	ug/L
WATSON 51	1/10/2024 06:26	1/18/2024 17:40	70284329028	Lead	<1.0	5	ug/L
WATSON 53	1/10/2024 06:28	1/18/2024 17:42	70284329029	Lead	<1.0	5	ug/L
WATSON 54	1/10/2024 06:30	1/18/2024 17:43	70284329030	Lead	<1.0	5	ug/L
WATSON 55	1/10/2024 06:31	1/18/2024 17:45	70284329031	Lead	<1.0	5	ug/L
WATSON 58	1/10/2024 06:32	1/18/2024 17:46	70284329032	Lead	<1.0	5	ug/L
WATSON 60	1/10/2024 06:33	1/18/2024 17:48	70284329033	Lead	<1.0	5	ug/L
WATSON 62	1/10/2024 06:34	1/18/2024 17:49	70284329034	Lead	<1.0	5	ug/L
WATSON 65	1/10/2024 06:25	1/18/2024 17:51	70284329035	Lead	<1.0	5	ug/L
WATSON 70	1/10/2024 06:11	1/18/2024 17:53	70284329036	Lead	<1.0	5	ug/L
WATSON 72	1/10/2024 06:12	1/18/2024 17:57	70284329037	Lead	<1.0	5	ug/L
WATSON 74	1/10/2024 06:13	1/18/2024 17:59	70284329038	Lead	<1.0	5	ug/L
WATSON 76	1/10/2024 06:14	1/18/2024 18:00	70284329039	Lead	<1.0	5	ug/L
WATSON 78	1/10/2024 06:15	1/18/2024 18:02	70284329040	Lead	<1.0	5	ug/L
WATSON 80	1/10/2024 06:16	1/18/2024 18:06	70284329041	Lead	<1.0	5	ug/L
WATSON 82	1/10/2024 06:17	1/18/2024 18:11	70284329042	Lead	<1.0	5	ug/L
WATSON 83	1/10/2024 06:18	1/18/2024 18:18	70284329043	Lead	<1.0	5	ug/L
WATSON 87	1/10/2024 06:10	1/18/2024 18:20	70284329044	Lead	1.9	5	ug/L
WATSON 88	1/10/2024 06:24	1/18/2024 18:22	70284329045	Lead	<1.0	5	ug/L
WATSON 90	1/10/2024 06:40	1/18/2024 18:23	70284329046	Lead	<1.0	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb